



| MINIMUM STANDARDS | | | | | | |
|---------------------|------|-----------------|---------------|------------------------------|----------------------------|------------|
| | ITEM | DESCRIPTION | THOROUGHFARE | COMM., IND. & RES. COLLECTOR | RESIDENTIAL THROUGH STREET | LOCAL |
| STANDARD DIMENSIONS | I | RIGHT-OF-WAY | * | 61' | 60' | 50' |
| | II | B\B CURB | * | 41' | 37' | 33' |
| | III | SIDEWALK WIDTH | * | 5' | 4' | 4' |
| | IV | CURB LAWN WIDTH | * | 4' | 7' | 4' |
| AGGREGATE BASE | V | ITEM 448 | 1-1/2" MIN | 1-1/2" MIN | 1-1/2" MIN | 1-1/2" MIN |
| | VI | ITEM 448 | 1-1/2" | 1-1/2" | 1-1/2" | 1-1/2" |
| | VII | ITEM 301 | 6" | 5" | 4" | 3" |
| | VIII | ITEM 304 | 9" | 9" | 9" | 9" |
| ASPHALT BASE | V | ITEM 448 | 1-1/2" MIN | 1-1/2" MIN | 1-1/2" MIN | 1-1/2" MIN |
| | VI | ITEM 448 | 1-1/2" | 1-1/2" | 1-1/2" | 1-1/2" |
| | VII | ITEM 301 | 8" 2 LIFTS | 7" 2 LIFTS | 6" | 5" |
| | VIII | ITEM 304 | 4" | 4" | 4" | 4" |

* SEE DESIGN CRITERIA AND CITY ENGINEER
A 10' EASEMENT IS TO BE PLACED ALONG THE RIGHT-OF-WAY LINE.

NOTES

- A. ALL WORK TO CONFORM TO ODOT CONSTRUCTION AND MATERIAL SPECIFICATIONS LATEST REVISION UNLESS OTHERWISE SPECIFIED.
- B. ITEM 407 TACK COAT, SHALL BE REQUIRED WHEN 10 DAYS HAVE ELAPSED BETWEEN BITUMINOUS PAVEMENT LIFTS UNLESS OTHERWISE SPECIFIED BY THE ENGINEER. APPLICATION RATE IS 0.08 GALLON PER SQUARE YARD.
- C. ALL BUTT JOINTS SHALL BE SEALED WITH PG 64-22 WITHIN 24 HOURS AFTER PLACEMENT OF ITEM 448.
- D. STANDARD DIMENSIONS FOR (II) B\B CURB AND (IV) CURB LAWN WIDTH ASSUME PARKING ON BOTH SIDES.
- E. SIDEWALK OF 4' WIDTH MAY BE APPROVED BY THE CITY ON ARTERIAL, INDUSTRIAL AND COMMERCIAL.
- F. IN AREAS WITH HIGH POTENTIAL OF PUSHING, SHOVING OR HEAVING, USE ITEM 448 ASPHALT CONCRETE SURFACE COURSE TYPE 1H, PG. 70-22. IN SMALL QUANTITY AREAS USE TYPE 1, PG 64-22 WITH GILSONITE ADDITIVE.
- G. ALL NEW STREETS ARE TO BE CONSTRUCTED USING ASPHALT. CONCRETE PAVEMENT WILL NOT BE ACCEPTED.
- H. ITEM 408 PRIME COAT SHALL BE APPLIED ON ITEM 304 AGGREGATE BASE AT THE RATE OF 0.4 GAL/SY PRIOR TO ASPHALT.